



产品认证证书

证书编号：CQC16003142018

申请人名称及地址

厦门唯恩电气有限公司
厦门市同安区大同街道城北工业区

制造商名称及地址

厦门唯恩电气有限公司
厦门市同安区大同街道城北工业区

生产企业名称及地址

厦门唯恩电气有限公司(V024557)
厦门市同安区朝元路城北工业区 759-3

产品名称和系列、规格、型号

电连接器

型号见附件

产品标准和技术要求

GB/T34989-2017

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC11-462222-2011 认证规则的要求，特发此证。

发证日期：2018 年 07 月 17 日

本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书，证书首次颁发日期：2016 年 04 月 11 日

主任：_____



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0119158



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC16003142018

NAME AND ADDRESS OF THE APPLICANT

Xiamen WAIN Electrical Co., Ltd.
Chengbei Industrial Zone, Datong Street, Tong'an District, Xiamen City

NAME AND ADDRESS OF THE MANUFACTURER

Xiamen WAIN Electrical Co., Ltd.
Chengbei Industrial Zone, Datong Street, Tong'an District, Xiamen City

NAME AND ADDRESS OF THE FACTORY

Xiamen WAIN Electrical Co., Ltd. (V024557)
No.759-3 Chengbei Industrial Zone, Chaoyuan Road, Tong'an District, Xiamen

PRODUCT NAME, MODEL AND SPECIFICATION

Electrical Connectors
Model See Appendix

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T34989-2017

TYPE OF CERTIFICATION SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462222-2011 .

Valid from: Jul.17,2018

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

Date of original issued: Apr.11,2016

President: _____

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0119158



产品认证证书

附录:

第 1 页 共 1 页

证书编号: CQC16003142018

纸号: 119158

产品名称 (中文):

电连接器

规格和型号:

HE-006-F.AV.L+HE-006-F.AV.R 16A 500V
HE-006-M.AV.L+HE-006-F.AV.L 16A 500V
HE-006-M.AV.R+HE-006-F.AV.R 16A 500V
HE-010-M.AV.L+HE-010-F.AV.L 16A 500V
HE-010-M.AV.R+HE-010-F.AV.R 16A 500V
HE-016-M.AV.L+HE-016-F.AV.L 16A 500V
HE-016-M.AV.R+HE-016-F.AV.R 16A 500V
HE-024-M.AV.R+HE-024-F.AV.R 16A 500V
HE-024-M.AV.L+HE-024-F.AV.L 16A 500V

无分断能力 固定连接器 I类 不带联锁 螺纹端子连接 -40T125 污染等级 3 无负载 500
次操作循环 灼热丝 850℃ 球压 125℃ 针焰 10s PTI175

注: 此附录与证书同时使用时有效。

主任: _____



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>